



QPS Evaluation Services Inc
Testing, Certification and Field Evaluation Body
Accredited in Canada, the USA, and Internationally

File LR1311

CERTIFICATE OF COMPLIANCE
(ISO TYPE 3 CERTIFICATION SYSTEM)

Issued to	Raytec Ltd.
Address	Unit 3 Wansbeck Business Park, Rotary Parkway, Ashington, Northumberland, NE63 8QW, United kingdom
Project Number	LR1311-2
Product	SPARTAN LED Linear Luminaire
Model Number	SPX-WL-XX-STD
Ratings	Class I, Div 2, Gp ABCD T4 toT6 Class II, Div 1, Div 2, Gp E,F,G Tamb = -40°C to +45°C or +55°C Enclosure Type 4X
	110-254 Vac 50/60 Hz or 18-40 Vdc 34 or 68 W
Applicable Standards	CSA C22.2 No. 94.2-07, CSA C22.2 No 25 – M1966 CSA C22.2 No. 213-M1987, CSA C22.2 No. 250.13-14 ANSI/ISA 12.12.01-2013, UL 1203 – 5th ed., UL 50E 1st ed UL 8750-1st ed.
Factory/Manufacturing Location	Same as Applicant

Statement of Compliance: The product(s) identified in this Certificate and described in the Report covered under the above referenced project number have been investigated and found to be in compliance with the relevant requirements of the above referenced standard(s). As such, they are eligible to bear the QPS Certification Mark shown below, in accordance with the provisions of QPS's Service Agreement.



Issued By: **Dave Adams, P. Eng.**
 Manager, Hazardous Locations Dept. [Ex. Equipment]

Signature: 

Date: October 19, 2015