



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEX Scheme visit www.iecex.com

Certificate No.: IECEX CML 14.0001 Issue No: 2 Certificate history:
Status: **Current** Page 1 of 4 [Issue No. 2 \(2015-02-17\)](#)
Date of Issue: **2015-02-17** [Issue No. 1 \(2014-12-18\)](#)
Applicant: **Raytec Ltd** [Issue No. 0 \(2014-04-28\)](#)
Unit 3, Wansbeck Business Park
Rotary Parkway
Ashington
Northumberland
NE63 8QW
United Kingdom

Electrical Apparatus: **Spartan SPX Luminaires**
Optional accessory:

Type of Protection: **Increased safety, encapsulated, dust protection**

Marking:
Ex e mb IIC T6 Gb or Ex e mb IIC T5 Gb or Ex e mb IIC T4 Gb
Ex tb IIIC T82°C Db or Ex tb IIIC T98°C
Up to -52°C to +55°C (dependant on model) REFER TO ANNEX

Approved for issue on behalf of the IECEX
Certification Body:

M D Shearman FlinstMC

Position:

Managing Director

Signature:
(for printed version)

Date:

17/02/2015

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEX Website](#).

Certificate issued by:

Certification Management Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port
CH65 4LZ
United Kingdom





IECEX Certificate of Conformity

Certificate No: IECEX CML 14.0001

Issue No: 2

Date of Issue: **2015-02-17**

Page 2 of 4

Manufacturer: **Raytec Ltd**
Unit 3, Wansbeck Business Park
Rotary Parkway
Ashington
Northumberland
NE63 8QW
United Kingdom

Additional Manufacturing
location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition:6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-18 : 2009 Edition:3	Explosive atmospheres Part 18: Equipment protection by encapsulation "m"
IEC 60079-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
IEC 60079-7 : 2006-07 Edition:4	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[GB/CML/ExTR15.0009/00](#)
[GB/CML/ExTR14.0025/00](#)

[GB/CML/ExTR14.0001/00](#)

[GB/CML/ExTR14.0006/00](#)

Quality Assessment Report:

[GB/SIR/QAR13.0018/00](#)



IECEx Certificate of Conformity

Certificate No: IECEx CML 14.0001

Issue No: 2

Date of Issue: **2015-02-17**

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The Spartan SPX FL** luminaire is fitted with LED lamp modules and is rated at 110V to 254 V, 50/60 Hz. The luminaire may be supplied with a battery pack and inverter to enable operation in 'emergency' mode. The luminaire enclosure comprises, front, centre, and rear cast aluminium housings that are fixed together with bolts. There are fixing points for a mounting bracket that enable the luminaire to be fixed in any orientation, alternative fixing points are also provided for additional mounting accessories. Inside the centre housing there are two independent encapsulated power supplies (electronic control gear) and supply /connection terminal blocks, cable entries are also present for the connection of mains electrical supply. Internal and external earth points are available. The front housing has a toughened soda lime glass lens that is available in clear or coloured options. Internally the LED's are mounted onto two independent IMS PCBs which are attached to the rear heat sink, each PCB utilises twelve LED's which can be white, infra-red, coloured or a combination.

The LED's must be fitted with individual optics, these optics are available in a range of beam patterns to suit the end user application. The LED's/optics are positioned in groups of four, each group of four is in turn covered with an individual clear polycarbonate cover which is then partially encapsulated.

See Annex for full description and Conditions of Manufacture

CONDITIONS OF CERTIFICATION: NO



IECEX Certificate of Conformity

Certificate No: IECEx CML 14.0001

Issue No: 2

Date of Issue: **2015-02-17**

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

This variation introduces the following modifications:

- The introduction of an alternative bulkhead luminaire version, housed in a modified enclosure. The battery pack and inverter modules have been changed as part of this addition. The description has changed to include the bulkhead version.
- Marking expanded, refer to Annex.

Annex:

[IECEX CML 14_0001 Annex Issue 2.pdf](#)

Annexe to: IECEx CML 14.0001 Issue 2
Applicant: Raytec Ltd.
Apparatus: Spartan SPX FL** Luminaire



Marking

FL** Version HV & LV	FL** Version Emergency	Lower Ambient Extension
Ex e mb IIC T6 Gb -50°C to +48°C Ex e mb IIC T5 Gb -50°C to +55°C Ex e mb IIC T4 Gb -50°C to +55°C Ex tb IIIC T82°C Db -50°C to +55°C IP66	Ex e mb IIC T6 Gb -20°C to +48°C Ex e mb IIC T5 Gb -20°C to +55°C Ex e mb IIC T4 Gb -20°C to +55°C Ex tb IIIC T82°C Db -20°C to +55°C IP66	HV & LV versions may be marked with a lower ambient of -52°C when fitted with appropriate terminals.
BL** Version HV & LV	BL** Version Emergency	
Ex e mb IIC T5 Gb -50°C to +48°C Ex e mb IIC T4 Gb -50°C to +55°C Ex tb IIIC T98°C Db -50°C to +55°C IP66	Ex e mb IIC T5 Gb Ex tb IIIC T98°C Db -20°C to +46°C IP66	

Description

The Spartan SPX FL** luminaire is a range of LED luminaires. There are three sizes available in the range FL12 (Small) FL24 (Medium) and FL48 (Large). All size enclosures are offered as LV (Low Voltage); rated at 18V - 30V AC / 18V – 40V DC or HV (High Voltage); rated at 110V – 254V AC. The HV luminaires may be supplied with a battery pack and inverter to enable operation in ‘emergency’ mode.

The luminaire enclosure comprises, front, centre, and rear cast aluminium housings that are fixed together with bolts. There are fixing points for a mounting bracket that enable the luminaire to be fixed in any orientation, alternative fixing points are also provided for additional mounting accessories.

Inside the centre housing there are two independent encapsulated power supplies (electronic control gear) and supply /connection terminal blocks, cable entries are also present for the connection of mains electrical supply. Internal and external earth points are available.

The front housing has a soda lime toughened glass lens that is available in clear or coloured options. Internally the LED’s are mounted onto two independent IMS PCBs which are attached to

Unit 1, Newport Business Park
 New Port Road
 Ellesmere Port
 CH65 4LZ

T +44 (0) 151 559 1160
E info@cmllex.com

www.cmllex.com

Company Reg No. 8554022 VAT No. GB163023642





the rear heat sink, each PCB utilises twelve LED's which can be white, infra-red, coloured or a combination.

The LED's must be fitted with individual optics, these optics are available in a range of beam patterns to suit the end user application. The LED's/optics are positioned in groups of four, each group of four is in turn covered with an individual clear polycarbonate cover which is then partially encapsulated.

The emergency version utilises a modified rear housing which incorporates a rechargeable battery pack, connection terminal block and encapsulated fuse. An optional encapsulated single green LED can be fitted to the wall of the centre housing which provides the end user with an indication that the emergency system is healthy.

The luminaire is available in three sizes, small, medium and large. The medium variant as described above, the small variant which only utilises one power supply/LED board and the larger variants which consist of a number of medium luminaires fixed together with unions and alternative mounting brackets.

The small, medium and large variants may all be fitted with an optional encapsulated photocell which is located in the wall of the centre housing positioned to suit the customer's application. Also on all variants a 'Vario' holographic diffuser film may be fitted behind the glass to give alternative light patterns.

The front and middle/rear housing of the luminaires may be split to allow the LED assembly to be mounted remotely from the power supply/emergency enclosure.

An EMC filter module may be fitted as an optional extra, this is an additional encapsulated board, located in place of the terminal block bracket (when fitted).

A Spartan SPX FLT** transportable variant of luminaire is available which consists of one of the luminaires above mounted in a sturdy frame and supplied with suitable cable and certified ATEX plugs and sockets.

A Bulkhead variant of the luminaire is available, the Spartan SPX BL24. Based on the FL24 floodlight it is modified to utilise a narrower enclosure and run at half of the power. It is offered as standard with the HV version rated at 110v – 254v AC, or as emergency where it is supplied with a battery pack and inverter.

The BL24 is designed for wall mounting in any orientation using steel brackets at the back of the luminaire. The enclosure consists of a front cover and rear body and utilises the power supply, inverter, control board and modified light engine from the FL24. The BL luminaire can be offered as transportable and with an optional photo cell.



Condition of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- Where the product incorporates certified components the manufacturer shall ensure that any changes to those components do not affect the compliance of the certified product that is the subject of this certificate.
- A dielectric strength test shall be carried out on all units manufactured in accordance with EN 60079-7:2007 clause 7.1 and EN 60079-18:2009, clause 9.2, at 1508 Vac for 1 minute, or alternatively at 1.2 times this test voltage for 100 ms. Alternatively, a 1.4 times d.c. voltage dielectric strength test may be carried out. No breakdown shall occur. Tests shall be carried out between each circuit and earth and between each circuit and the surface of encapsulated parts.
- A visual inspection shall be carried out on the encapsulated parts to check for damage, in accordance with EN 60079-18:2009, clause 9.1.

Condition of Certification

None